

ORDINANCE NO. 0-96-68

AN ORDINANCE AMENDING ORDINANCE NO. A-517 ENTITLED "AN ORDINANCE TO PROVIDE FOR PLUMBING INSPECTIONS FOR ALL PLUMBING WHEREVER WATER ORIGINATES FROM THE CONWAY MUNICIPAL WATER WORKS SYSTEM: PROVIDING FOR PLUMBING INSPECTORS: PROVIDING FOR ADOPTION OF THE ARKANSAS STATE PLUMBING CODE: FIXING FEES FOR SUCH PLUMBING INSPECTION: PROVIDING FOR DISCONTINUANCE OF WATER SERVICE: REPEALING ORDINANCES OR PARTS OF ORDINANCES IN CONFLICT HERewith: DECLARING AN EMERGENCY AND FOR OTHER RELATED PURPOSES."

SECTION 3 SHALL ~~BE~~ AMENDED AS FOLLOWS:

- (a) Section 10.1.5 of said code being hereby adopted shall be and hereby is amended to read as follows:

"10.1.5 Water Service Pipe (Materials).

Cold water service piping shall be cast iron pipe, ductile iron pipe, type K or L copper tubing or schedule 40 PVC except when such service is under concrete, then such pipe shall be cast iron pipe, ductile iron pipe or type K copper tubing.

- (1) Schedule 40 PVC pipe shall be limited to sizes 2 inches and smaller and may be installed from a point 5 feet from the water meter to the house or building being served.
- (2) The water pipe from the water meter to a point at least 5 feet from the meter shall be cast iron pipe, ductile iron pipe or type K or L copper tubing."

- (b) Section 11.2.1 of said code shall be and hereby is amended to read as follows:

"11.2.1 Separate Trenches.

The building sewer, when installed in a separate trench from the water service pipe, shall be cast iron pipe, ductile iron pipe, clay sewer pipe or schedule 40 PVC sewer pipe (4 inch in diameter only). Joints shall be watertight and rootproof."

EMERGENCY. This Ordinance being necessary for the protection of the health, safety and welfare of the City of Conway, an emergency is hereby declared to exist and this ordinance shall take effect and be in force from and after its passage and publication.

PASSED 8-13-96.

APPROVED:


MAYOR

ATTEST:


CITY CLERK