

② Same  
000356

Doc#2008- 352  
Date 01/04/2008  
01:26:23 PM  
Filed & Recorded in  
Official Records of  
Faulkner County  
RHONDA LONG  
FAULKNER COUNTY CIRCUIT CLERK  
Fees \$20.00

29083

0-07-161  
ORDINANCE NO. 0-07-161 By \_\_\_\_\_ D.C.

**AN ORDINANCE AMENDING SECTION 11.04.25 OF THE CONWAY MUNICIPAL CODE; AND FOR OTHER PURPOSES:**

WHEREAS, the City of Conway is working toward continually improving the requirements for building within the city limits, we request the following amendment be made to the following section of the Municipal Code:

**NOW, THEREFORE, BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF CONWAY, ARKANSAS:**

**Section 1:** That 11.04.25 section C, W, X, & Y of the Conway Municipal Code is hereby amended to read as follows:

(C) Residences and Apartments shall be done with wire not smaller than No. 14 gauge wire, allowing ten (10) outlets per 15 amp circuit and twelve (12) outlets per 20 amp circuits. Provided, however, laundry rooms shall have not more that two (2) outlets per circuit, and kitchen above counters shall have not more than (4) four duplex receptacles per circuit installed with wire not smaller than No. 12 gauge.

(W) Non Metallic sheathed cable will only be allowed in R-1, R-2 and Multi-Family Residence.


(X) Aluminum wire is prohibited other than feeders and service with no smaller that No. 4 gauge.

(Y) Alternative Power Source \$25.00  
(such as solar systems, fuel sales, etc.)


**SECTION 2.** All ordinances in conflict herewith are repealed to the extent of that conflict.

**PASSED** this 18<sup>th</sup> day of December 2007.

Approved:

  
Mayor Tab Townsell

Attest:

  
Michael O. Garrett  
City Clerk/Treasurer